

June 19, 2026**Addendum No. 03****File Reference Number: RFP 2026 031****Title: Cochrane Station Parking Lot Paving****RE: Additional work and clarification**

CLARIFICATIONS/QUESTIONS:**Item 1: Appendix D – Schedule of Prices**

For Item No. 18 under the Schedule of Prices, are the interlocking pavers to be replaced with the removed ones, or with new pavers?

Answer: All removed pavers are to be replaced with new pavers. The existing pavers that are removed must be disposed of.

Item 2: The Earth Excavation special provision states that “locations for the stockpiling of excess soils shall be within the project limits.”

Can ONTC please provide the proposed stockpile locations as well as the permitted haul routes?

Answer: If the excess materials cannot be utilized within the project limits, they are to be disposed of on ONTC property located at the east end of the site. This area can be accessed via 2nd Street, as shown on the map below. Following disposal, the contractor is responsible for spreading and leveling the material in the designated area.



Item 3: Can you please clarify the scope and extent of testing required.
Is any testing required if we are stockpiling the material within the project limits.

Answer: ONTC has determined that testing is not required, as all materials will be relocated within ONTC property.

Item 4: Please clarify: Under Addendum No. 02, additional platform curb is 436 m length same as item no 17. Is this the same quantity or duplicated?

Answer: The additional platform curb should have read approximately 125 m not 436 m.

This Addendum hereby forms part of the RFP.

Regards,

Brinda Ranpura
Procurement Contracts Specialist
brinda.ranpura@ontarionorthland.ca